Office

370 S. Winchester

Tract No._____ Lot No._ M-0388

CITY OF SAN JOSE **BUILDING DEPARTMENT**

APPLICATION FOR BUILDING PERMIT

Date 12/6 1966 Permit No. 52026-4

Application is hereby made for a permit to BUS

a 1 story, Type IV BUS Building

at 370 So. WINCHESTER BD.

to be occupied only as OFFICE BLDG

in accordance with Plans, Specifications and Plot-plan filed herewith.

Use Zone C3

Occupancy F2

Parking Space 39

Fire Sprinkler NO

Estimated Value of Improvements, $ 100,000.

Exemption from requirement for State of California for Contractor's License is hereby claimed by undersigned:

as owner ☐ statement filed ☐

Undersigned attests that his State of California Contractor's License # 216060SB-1 is in full force and effect and properly authorizes this application.

San Jose City Business License # 4-11198.

I certify that in the performance of the work for which this permit is issued I shall not employ any person in any manner so as to violate the workmen's compensation laws of California.

Owner McDONNELL & Co. INC Address 370 S. WINCHESTER S.J.

By Clifford Kramer Address 777 No. First St. S.J.

McCALL L. SWENSON CO. INC.

370 S. Winchester Mc Donnell & Co. Inc

RECORD OF INSPECTION

Foundation _____ Frame 2-27-67 Amos

Stucco 1-19-67 Amos Finish 2-28-67 Amos

Pier (all) 12-21-66 3 yards

8" Lift @ Block Course 12-27-66 Amos

8 Cols Fin B/Block 12-28-66 Amos

So 1/2 Slab OK 12-21-66 Amos

No 1/2 Slab OK 1-3-67 Amos

Roof Nail OK 1-11-67 Amos

Ext Pl Nail OK 1-16-67 Amos

Rough OK North Room 1-17-67 Amos

Rough Sw OK No & West Side 1-18-67 Amos

Int Wood Frame OK 1-20-67 Amos

T-Bar Suspension Sys OK 1-26-67 Amos

Provide Fire Ext (1-Type 2A) & Leave with Fire 2-27-67 Amos

Form 280-1 — 10M — 5/66

1. LOCATION 370 S. Winchester

2. DATE RCD. 7-22-77

3. TIME RCD. 11:35

4. READY AM ( ) ANYTIME ( ) PM (X) SPECIFY mow
Late

5. TYPE OF INSPECT. F/W

6. AREA 11A

7. INSPT. MADE TIME 4:00 DATE 8/3/77

8. APPROVED ( ) DISAPPROVED (✓)

9. REMARKS: Manager N/in, No plans or insp. Card.

INSPECTOR Sandoval

280 - 671

WHITE - FILE YELLOW - INSPECTOR PINK - OFFICE

1. LOCATION 370 S. Winchester

2. DATE RCD.

3. TIME RCD.

4. READY AM ( ) ANYTIME ( ) PM ( ) SPECIFY

5. TYPE OF INSPECT. F/W

6. AREA 13

7. INSPT. MADE TIME 1:30 DATE 8-17-77

8. APPROVED ( ) DISAPPROVED (✓)

9. REMARKS: No Change @ Tinted Glass Panels.

INSPECTOR Sandoval

280 - 671

WHITE - FILE YELLOW - INSPECTOR PINK - OFFICE

1. LOCATION	2. DATE RCD.	3. TIME RCD.
370 S. Winchester	8-3-77	11:04

4. READY	5. TYPE OF INSPECT.	6. AREA	7. INSPT. MADE
AM ( ) ANYTIME ( ) PM (X) SPECIFY Thurs	FIR	11A	TIME 4:20 DATE 8/4/77

8. APPROVED ( )
DISAPPROVED (✓)

9. REMARKS:
Fire Extr. (2) N/installed, Provide mirror in toilet Rms N/ more than 40" from floor to bottom of mirror, 3 floor to clg glass panels N/labeled & unprotected, Need to verify fire retardant of wd panels & trim, No insp. card

INSPECTOR Sandoval

280 - 671

WHITE - FILE YELLOW - INSPECTOR PINK - OFFICE